

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF NORTHERN ROCKCASTLE)	
COUNTY WATER DISTRICT FOR A DEVIATION)	
FROM THE REQUIREMENTS OF 807 KAR 5:066,)	CASE NO. 89-284
SECTION 5(4), REGARDING WATER STORAGE)	

O R D E R

By application received October 2, 1989, Northern Rockcastle County Water District ("Northern Rockcastle") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Northern Rockcastle states in its application that its average daily water usage, including unaccounted-for water, is approximately 110,000 gallons, and its current water storage capacity is 20,000 gallons.

The Commission, having reviewed the application and being advised, finds that:

1. Northern Rockcastle is not in compliance with the requirements of Commission Regulation 807 KAR 5:066, Section 5(4).

2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Northern Rockcastle should be given until November 1, 1992 to bring it within compliance of the Commission's water storage requirements.


IT IS THEREFORE ORDERED that:


1. Northern Rockcastle be and it hereby is given until November 1, 1992 to comply with the provisions of 807 KAR 5:066, Section 5(4).


2. Northern Rockcastle shall take all necessary actions to bring its water storage facilities within compliance of the Commission regulations prior to the expiration date of the deviation herein granted.

Done at Frankfort, Kentucky, this 27th day of October, 1989.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:

Executive Director